



PowerSystems
On behalf of SP Distribution Ltd & SP Transmission Ltd

Information about apparatus given on this drawing is indicative only as the original depths and lines of cables and pipes may have been changed by persons unknown. Normally electricity cables are laid in trenches between 450mm and 1m deep, and gas pipes are laid in trenches between 375mm and 1m deep but cellars or structures such as bridges may prevent cables and pipes being laid at these standard depths. Also, the depth may be above or below the standard due to regrading of the surface or other work after the cables or pipes are laid. Where known, non-standard depths are indicated. Any interference with, or damage to, apparatus may result in serious accident. Health and Safety Executive booklet HS(G) 47 provides information on the avoidance of danger from underground services. Authorities and contractors will be held liable both for the full cost of repairs to apparatus and all claims made against by Third parties as a result of interference or damage. Further advice may be obtained by contacting the above office. Reproduced from Ordnance Survey maps by kind permission.

SCALE :- 1:1250

Date :- 18 Feb 2008

Produced by :- BURT5423

Produced for :-

X Coordinate :- 248960
Y Coordinate :- 664288